

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200534
Address: 3201 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	John Morris	Failed	Friday, November 06, 2020

Corrective Action Required:

1	Misc	-as built plot reflects on site conditions but as stated in TCO inspection report, grade must fall minimum 6" in the first 10' from foundation per code or provide swale between properties.
---	------	--

Comments: