

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201772
Address: 3202 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	John Morris	Failed	Friday, November 06, 2020

Corrective Action Required:

1	Miscellaneous Correction	-Deficient erosion control, methods require continuous maintenance. Reestablish erosion control at curb lines within two days. -Immediate Street clean up required -No further inspections until issues are resolved
---	--------------------------	---

Comments: