

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200763  
Address: 2050 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                      | Inspector:      | Outcome: | Date:                     |
|----------------------------------|-----------------|----------|---------------------------|
| <b>Rated Assembly Inspection</b> | Michael Harkins | Partial  | Friday, November 06, 2020 |

Informational:  
1 Misc

- 1ST LAYER 5/8 ON NORTH WALLS DETAIL P-1 & P-2
- UL 301 -
- 1ST LAYER ON SOUTH WALLS -
- 2ND LAYER ON SOUTH WALL IN STARBUCKS UNIT OK TO TAPE -
- 2ND LAYER ON NORTH & SOUTH WALLS MIDDLE UNIT OK TO TAPE -

**Comments:**