

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20193581

Address: 2001 NW SHAMROCK AVE, Unit:IR, LEES SUMMIT, MO 640812001 NW SHAMROCK AVE, LEES  
SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Detention Basin</b>	Ronald Paynter	Failed	Monday, November 09, 2020

Informational:

1	Misc	Ben's crew poured the floor for the end sections of lines B and D. RP 8-17-20
---	------	---

Informational:

2	Misc	Ben's crew formed up the wing walls for the end sections of lines B and D. RP 8-19-20
---	------	--

Corrective Action Required:

3	Misc	Talked with Norm about the status of the detention basin not draining. They need to find and fix the issue. RP 11-3-20
---	------	---

Corrective Action Required:

4	Misc	Basin is still holding water 4 days after being unclogged. RP 11-9-20
---	------	---

**Comments:**