

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202579  
Address: 4700 NE SARATOGA CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                                  | Inspector:  | Outcome: | Date:                        |
|--------------------------------------------------------------|-------------|----------|------------------------------|
| <b>Underslab Plumbing Inspection</b><br><b>- Residential</b> | John Morris | Failed   | Monday, November<br>09, 2020 |

Corrective Action Required:

|   |      |                                                                 |
|---|------|-----------------------------------------------------------------|
| 1 | Misc | Provide positive or neutral slope for interior under slab drain |
|---|------|-----------------------------------------------------------------|

**Comments:**