

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200763  
Address: 2050 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Michael Harkins	Partial	Monday, November 09, 2020

Informational:  
1 Misc

- 1ST LAYER 5/8 ON NORTH WALLS DETAIL P-1 & P-2
- UL 301 -
- 1ST LAYER ON SOUTH WALLS -
- 2ND LAYER ON SOUTH WALL IN STARBUCKS UNIT OK TO TAPE -
- 2ND LAYER ON NORTH & SOUTH WALLS MIDDLE UNIT OK TO TAPE -
- 2ND LAYER NORTH UNIT OK TO TAPE -

**Comments:**