



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20200987	Date:	November 09, 2020
Project Title:	OUR LADY OF THE PRESENTATION - INTERIOR ALTERATIONS	Applicant:	
Location:	150 NW MURRAY RD, LEES SUMMIT, MO 64081	PROGRESSIVE ELECTRONICS INC	
Type of Work:		6102 ARLINGTON AVE	
Occupancy Group:	A-3	RAYTOWN, MO 64133	
Description:	INTERIOR ALTERATIONS TO EXISTING CHURCH - REMODEL OF WORSHIP SPACE, GATHERING SPACE, OFFICES AND MEETING ROOMS	Primary: (816) 765-5750	

**invite planner to verify rooftop screening
Construction Type: Type IIB (Unprotected)
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Rejected

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.
(Informational Purposes)
Call (816)969-1300 to schedule testing.

2. (Action Required)

1. Update records Showing 2018 I-series and NFPA 2016 edition
2. Add strobes in Restrooms by North Gathering(103)
3. Add notification in meeting rooms/ office spaces.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.