## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSUBD20192738 Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection	1:	Inspector:	Outcome:	Date:
Water Lin	e - Hydrostatic Test	John DiMauro	Passed	Monday, November 09, 2020
Informatio	onal:			
1	Misc	John DiMauro 11/09/2020 3:07 PM		
		l observed the hydrostatic pressure test for the water line. The line held at 160 PSI for 2 hours with no drop.		

Comments: