

Inspection Summary

Permit #: PRCOM20200845, Building Permit - Commercial

ST LUKE'S EAST HOSPITAL FLEX CAPACITY ADDITION

Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Robb Popp	Partial	Monday, November 09, 2020

Corrective Action Required

1 -FOLLOWING AREAS APPROVED:

CONDUIT FROM ELECTRICAL ROOM 1B108 ABOUT 100' TO SPLIT FOR PANELS B130 & B131, ROOM1B00J AND AMBULANCE BAY PANELS B125 & 126

POLE - CONDUIT;

SOUTH EXISTING POLE TO ADDED; NEW WEST POLES FROM SOUTH CORNER OF NEW LOT NORTH 200FT.

-CONDUIT FROM EXISTING BUILDING TO NEW GENERATOR AT NORTHEAST PARKING LOT

-CONDUIT FROM AMBULANCE BAY TO HELI PAD LIGHTS

-CONDUIT AND GROUND RODS FOR (7) LIGHT POLES IN SOUT AND SOUTHWEST LOT

-CONDUIT AND GROUND RODS FOR (2) LIGHT POLES AT AMBULANCE BAY

-CONDUIT FROM LIGHT POLE AT NW AMBULANCE BAY, UNDER HELI PAD TO QUAYSIDE BOX IN SOUTHWEST OF LOT FOR SITE LIGHTING LOOP

Occupancy Inspection - Engineering	Joe Starlin	Failed	Monday, November 09, 2020
---------------------------------------	-------------	--------	---------------------------------

Informational

1 The driveway approach for the ambulance bay has been completed and can be used for its

intended purpose. We are granting temporary occupancy for this ambulance bay only.

Comments:
