

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201210
Address: 2924 NW THOREAU DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Michael Harkins	Passed	Wednesday, June 10, 2020

Informational:

1	Misc	- 3RD PARTY FOOTING BY DAVID P AINSWORTH - - NOTES:UFER N FOUNDATION WALL BEHIND GARAGE ABOUT 10' IN OF NE CORNER -
---	------	--

Comments: