

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201210  
Address: 2924 NW THOREAU DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                 | Inspector:  | Outcome: | Date:                      |
|---------------------------------------------|-------------|----------|----------------------------|
| <b>Gas Service Inspection - Residential</b> | John Morris | Failed   | Tuesday, November 10, 2020 |

Corrective Action Required:

|   |      |                                                                                                                                        |
|---|------|----------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -Connect gas piping to all permanently installed gas appliances<br>-Gas piping not properly bonded due to the use of non-shielded CSST |
|---|------|----------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**