

November 6, 2020



City of Lee's Summit
220 SE Green Street
Lee's Summit, Missouri 64063


Attn: Building Inspections
Re: Veritasi Homes, 206 SW Lakeview Blvd, Lee's Summit, Missouri, Permit No.
PPRES2019-3251; frost footing inspection

To whom it may concern:

An inspection was conducted on Friday, November 6, 2020 regarding the above referenced. For reference purposes the house faces north. The frost footing was constructed around the entire perimeter. The interior frost type footing was in place to support the future kitchen island. The reinforcing steel and insulation were all installed in accordance the approved building plan. The soil is solid original soil and solid compacted crushed rock. The ground rod was installed. The concrete contractor, Mid States Form, was given permission to place the concrete into the forms. If you have questions, please contact me at my office.

Sincerely,
Logan & Associates, Inc.

Charles R. Logan, PE
President



cc: Mid States Form