## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## Temporary Certificate of Occupancy

Permit #: PRCOM20172523

Address: 245 NW KESSLER DR, LEES SUMMIT, MO 64081

Inspected On: Tuesday, November 10, 2020

**Inspected By:** John Morris

Expiration Date: 12/10/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.** 

Inspection: Outcome: Date:

Occupancy Inspection - John Morris Temporary C of O Tuesday, November

Codes Commercial 10, 2020

Corrective Action Required:

1 Misc -Complete exterior façade/siding

-complete exterior HVAC electrical installation

-Provide tamper resistant caps at condensing units

-Identify white insulated conductors used as current carrying

conductors, HVAC power supply at disconnect

TCO valid though 12/10/2020