CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20201458Address:4412 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, November 10, 2020
Corrective Action Required:			
1 Misc	-Steel gas line to flex gas line coupling cannot be concealed at 1st floor bedroom closet wall -Gas pressure at 0 psi, must maintain 10 psi for 15 minutes		

Comments: