

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202145
Address: 1862 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|------------------------------|
| All Rough Inspection - Residential | Khanh Nguyen | Failed | Wednesday, November 11, 2020 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | FRAMING: -Garage portal brace wall-install the missing 2" washers and nuts for the south side -lvl beam above doorway to front dining-provide support underneath point load |
|---|------|---|

Comments: