

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191069
Address: 500 SE M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Public Curb Inspection	Tom Taylor	Partial	Tuesday, November 10, 2020

Informational:
1 Misc Geo-Tech consultants provided concrete testing. Air was 6.5%, slump was 1" and temp of concrete is 70 degrees. 4 Cyl. Were taken.

Comments: