

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201545
Address: 1021 SW ARMIE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	John Morris	Failed	Wednesday, November 11, 2020

Corrective Action Required:

1	Misc	-Complete gas piping, connect to appliances per manufacturer instructions and pressure test piping
---	------	--

Corrective Action Required:

2	Misc	11/11/2020- Inspection denied due to lack of compliance with 11/06/2020 Erosion Control inspection report
---	------	---

Comments: