

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200763
Address: 2050 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Passed	Wednesday, November 11, 2020

Informational:

1	Misc	- 1ST LAYER 5/8 ON NORTH WALLS DETAIL P-1 & P-2 UL 301 - - 1ST LAYER ON SOUTH WALLS - - 2ND LAYER ON SOUTH WALL IN STARBUCKS UNIT OK TO TAPE - - 2ND LAYER ON NORTH & SOUTH WALLS MIDDLE UNIT OK TO TAPE - - 2ND LAYER NORTH UNIT OK TO TAPE - - FIRE TAPE FIRE CAULKING COMPLETE -
---	------	---

Comments: