

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20201867  
Address: 504 NW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, November 11, 2020

Corrective Action Required:

1	Miscellaneous Correction	504 NW Main St all rough  Address holes bored in top flange I joist above sump Seal top plate penetration behind furnace Provide boca plate master water closet Keyed plan notes #21 2x6 wall framing stairway ( have Tim stamp letter send to Dev tech to attach to permit) Keyed elevation notes #5 continuous ridge vent for concealed attic spaces Deck tension ties per plan Simpson stair hangers per plan
---	-----------------------------	--

**Comments:**