

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193177
Address: 1101 NE GOSHEN CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, November 11, 2020

Corrective Action Required:

1	Misc	7/15/20-REINSPECTION FEE ASSESSED
---	------	-----------------------------------

Corrective Action Required:

2	Misc	-Footing not inspected and approved by city. Have engineer submit inspection approval to city -Support end of deck beam; lag screw ledger board to rim band -At basement walkout doors, install security strike plates with 3" screws fasten to jamb studs; install 2-3" screw at each hinge -Tempered glass window required where located within 2 ft of door edge
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

****RE-INSPECTION FEE ASSESSED ON 7/15/20 HAS NOT BEEN PAID**

Comments: