

STUDIOARCHAEOS

November 11th, 2020

Michael Harkins
Inspector
City of Lee's Summit
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063

RE: **Permit # PRRES20201867**; 504 NW Main Street, Lee's Summit, Field
Inspection correction

I am writing to provide verification that the keyed plan note #21 on the floor plan of the permit set of drawings for the above referenced property was shown in error and that the walls around the stair opening should be framed with 2x4 wood framing.

Please let me know if you have any further questions.

Sincerely,



Timothy Louis Busse, AIA
Principal, Studio Archaeos
Archaeos LLC