CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20200044 Address: 420 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line - Hydrostatic Test	Joe Starlin	Passed	Wednesday, November 11, 2020
Informational:			

1 Misc

11-11-20 9:45am We started the test at 9:30am. It is at 200PSI for two hours. The test past, it held for two hours at 200PSI.

Comments: