

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20202923  
Address: 155 SW M 150 HWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	Patrick Schonfeldt	Partial	Wednesday, November 11, 2020

Informational:  
1 Misc - INSPECTED UNDERSLAB PLUMBING ON E SIDE TENANT (COFFEE SHOP) SIDE  
OF BUILDING, PRESSURE OVER 5 PSI

**Comments:**