

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20200103  
Address: 3122 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Monday, July 27, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- PROVIDE FLASHING HORIZONTAL TRIM ABOVE GARAGE DOOR -</li><li>- PROVIDE 5/8 ANCHOR BOLTS PFH PORTAL FRAME GARAGE PER PLAN -</li><li>- SECURE BATH EXHAUST WITH METALLIC TAPE -</li><li>- SECURE 2" DWV AT MIDPOINT -</li><li>- COMPLETE SNOW BLOCKING MASTER CLOSET &amp; TUB -</li><li>- PROVIDE STRUT PER PLAN AT RIDGE NW BEDROOM -</li><li>-</li><li>- PROVIDE JOIST HANGERS ABOVE BREAKFAST NOOK -</li><li>- HEADER OFF JOIST AT DWV GREAT ROOM -</li><li>- TIGHTEN ANCHOR BOLT LANDING -</li><li>- PROVIDE ANCHOR BOLTS SCH 40 COLUMNS BASEMENT -</li><li>- PROVIDE SOLID BLOCKING BETWEEN JOIST AT 36" OC 48" OF 3 JOIST SPACES PARRALLEL TO FOUNDATION WALL PER PLAN -</li></ul>
---	------	---

**Comments:**