

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193544
Address: 2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	Michael Harkins	Failed	Wednesday, November 11, 2020

Corrective Action Required:

1	Misc	2001 NW Shamrock Ave Rough plumbing Support vertical 2" & smaller DWV at midpoint Provide pressure on DWV system Support copper plumbing overhead training room (no bailing wire on sprinkler line) Boca plates throughout Room # 145 boca 136 140 133
---	------	---

Comments: