

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201764
Address: 2935 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, November 12, 2020

Corrective Action Required:

1	Misc	-joist hanger in garage at LVL connection -Complete gas piping and pressure test -Complete mechanical equipment installation
---	------	--

OK TO ROCK, DO NOT ROCK GARAGE UNTIL REINSPECT

Comments: