

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203968
Address: 1308 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Morris	Partial	Thursday, November 12, 2020

Corrective Action Required:

1	Misc	-provide circuit for interior & exterior emergency lighting rear of building. Will look at front of building interior & exterior exit/lighting circuit at above ceiling inspection. -plumbing alterations approved for future sink & slop sink in mechanical closet -metal stud framing approved
---	------	---

Do not cover rear exterior wall, inspection required for exit/lighting circuit

Comments: