

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203968
Address: 1308 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Morris	Partial	Thursday, November 12, 2020

Corrective Action Required:

1	Misc	-under slab for future water closet approved - ok to cover
---	------	------------------------------------------------------------

NOTE: Center line of water closet in ADA restroom is required to be 16-18" from adjacent wall

Comments: