

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20201700

Address: 3521 SW MARKET ST, LEES SUMMIT, MO 640823500 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Site Visit</b>	Tom Taylor	Partial	Friday, November 06, 2020

Informational:

1 Misc

On Thursday, 11-12-2020 the contractor got clarity from designer about curb configurations. About 80 LF of CG-1 curb was reinstalled because alignment was not right next to the CI in the front of the building. Also (2) squares of 6" driveway door bay building entrance was removed due to the wrong cross slope.

**Comments:**