

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192818
Address: 4064 NE CHAPEL MANOR DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Tuesday, November 10, 2020

Informational:

1	Miscellaneous Correction	-Obtain lawn sprinkler permit and backflow certification -Install cooktop
		Deck: -Provide missing bolts 16" OC in end joists at house -Provide angle clips on end joists not fully bearing on post -Provide (2) bolts in each rim joist to post connection -Provide graspable handrail at steps

Comments: