

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20201144
Address: 2939 SW ARBORWOOD DR, LEES SUMMIT, MO 64082
Inspected On: Monday, November 16, 2020
Inspected By: Patrick Schonfeldt
Expiration Date: 11/30/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Monday, November 16, 2020

Corrective Action Required:

1	Misc	-Splash blocks at all downspout and sump pump discharge locations, minimum 36" distance from foundation -Resolve outstanding inspection fee(s)
---	------	---

OK FOR TCO - EXPIRES 11/30/20