

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202692
Address: 2350 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	John Morris	Failed	Monday, November 16, 2020

Corrective Action Required:

2	Misc	-connect interior under slab draitile to sump pit -extend building drain from interior clean out under the footing, connection would not be accessible when concrete floor is poured
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: