

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201458  
Address: 4412 SW NAUTILUS PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Tuesday, November 17, 2020

Corrective Action Required:

1	Misc	-Fireblock HVAC chase in garage -truss hangers per plans -Truss bracing per plans -Steel gas line to flex gas line coupling cannot be concealed at 1st floor bedroom closet wall  OK TO INSULATE
---	------	---

**Comments:**