

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201877
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Mandrel	John Jackson	Passed	Tuesday, November 17, 2020

Informational:
1 Misc 11/17/20 Tuesday
Contractor (Holthouse) Pulled Mandrel through sanitary lines 1& 2 and passed
.

Comments: