

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20192822
Address: 4068 NE CHAPEL MANOR DR, LEES SUMMIT, MO 64064
Inspected On: Tuesday, November 10, 2020
Inspected By: Robb Popp
Expiration Date: 7/24/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Temporary C of O	Tuesday, November 10, 2020

Corrective Action Required:

1	Misc	-ADDENDUM: Deck beam overspanned. Double 2x12 beam for 10 ft joists can only span 9 ft 5 inches. Please refer back to the house plan for beam size
---	------	--