

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172535
Address: 269 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Morris	Partial	Wednesday, November 18, 2020

Informational:
1 Misc UG electric for lot lighting approved for island at maintenance building
Corrective Action Required:
2 Misc -uncover UG electric for monument sign

Comments: