

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201978
Address: 2938 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, November 18, 2020

Corrective Action Required:

1	Misc	-Fireblock deadspace between walls at refrigerator in kitchen - seal gaps at top plate Fireblock in deadspace -Secure NM and land to boxes in kitchen, seal floor penetrations -Secure NM and land to boxes at finished basement stairs -Seal top plate penetrations basement at stairs -Fireblock deadspace behind 1st floor shower and stairs -Attic access required, per plans -Complete Furnace install and complete gas line -Gas Pressure test required -Provide (2) bolts per post/rim connection at deck
---	------	--

OK TO INSULATE, REMOVE INSULATION FROM ANY INSPECTION ITEMS

Comments: