

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203653
Address: 3324 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, November 18, 2020

Corrective Action Required:

1	Misc	-ADT WIRELESS SMOKE ALARMS ARE NOT SUBSTITUTION FOR CODE REQUIREMENTS- - R314.3 SMOKE ALARMS REQUIRED IN BOTH BEDROOMS AND SMOKE/CO DETECTOR REQUIRED OUTSIDE VICINITY 10' OF SLEEPING ROOM -R314.6 SMOKE ALARMS SHALL RECEIVE PRIMARY POWER FROM BUILDING WIRING AND BACKUP FROM BATTERY
---	------	---

Comments: