

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200759  
Address: 2417 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	John Morris	Failed	Thursday, November 19, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>-Provide engineered documentation of retaining wall</li><li>-Only partial approval of driveway and sidewalk inspection, contact development services to resolve this issue</li><li>-Provide gutters and downspouts</li><li>-Downspouts and sump piping to discharge minimum 36" from foundation</li><li>-Remove trash and construction debris</li><li>-Final grade and sod per approved plot plan</li><li>-seal garage foundation and steps from interior of structure</li><li>-repair sheet rock in garage ceiling</li></ul>
---	------	---

Comments: