

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201863
Address: 3012 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, November 19, 2020

Corrective Action Required:

1	Miscellaneous Correction	-GAS PRESSURE AT 0 PSI, MUST MAINTAIN 10 PSI FOR 15 MINUTES
---	--------------------------	---

Comments: