

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20200845

Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086  
100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Mark Harding	Partial	Thursday, November 19, 2020

Corrective Action Required:

1	Miscellaneous Correction	-FOLLOWING AREAS APPROVED:  CONDUIT FROM ELECTRICAL ROOM 1B108 ABOUT 100' TO SPLIT FOR PANELS B130 & B131, ROOM1B00J AND AMBULANCE BAY PANELS B125 & 126  POLE - CONDUIT; SOUTH EXISTING POLE TO ADDED; NEW WEST POLES FROM SOUTH CORNER OF NEW LOT NORTH 200FT.  -CONDUIT FROM EXISTING BUILDING TO NEW GENERATOR AT NORTHEAST PARKING LOT -CONDUIT FROM AMBULANCE BAY TO HELI PAD LIGHTS -CONDUIT AND GROUND RODS FOR (7) LIGHT POLES IN SOUT AND SOUTHWEST LOT -CONDUIT AND GROUND RODS FOR (2) LIGHT POLES AT AMBULANCE BAY -CONDUIT FROM LIGHT POLE AT NW AMBULANCE BAY, UNDER HELI PAD TO QUAYSIDE BOX IN SOUTHWEST OF LOT FOR SITE LIGHTING LOOP. --2nd phase(of3) west of AMBO bays west to box.
---	-----------------------------	---

**Comments:**