CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201014

Address: 2751 NE DOUGLAS ST, Unit:V, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Piers/Caissons Inspection - Mark Harding Failed Thursday, November

Commercial 19, 2020

Corrective Action Required:

1 Misc incomplete- if using 3rd party ,ufer ground needs to be verified.

provide soil engineers report.

Comments: