

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201867  
Address: 504 NW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Thursday, November 19, 2020

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | - PROVIDE DECK TENSION TIES PER PLAN PROVIDE ACCESS FOR INSPECTION -<br>- ADDRESS HOLES BORED IN TOP CORD OF I JOIST ABOVE SUMP ( UNFINISHED MECH ROOM DO NOT COVER WITH INSULATION TILL RESOLVED CHECK ON FINAL -<br><br>- OK TO INSULATE & HANG ROCK - |
|---|------|--|

**Comments:**