

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201867
Address: 504 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Thursday, November 19, 2020

Corrective Action Required:

1	Misc	- PROVIDE DECK TENSION TIES PER PLAN PROVIDE ACCESS FOR INSPECTION - - ADDRESS HOLES BORED IN TOP CORD OF I JOIST ABOVE SUMP (UNFINISHED MECH ROOM DO NOT COVER WITH INSULATION TILL RESOLVED CHECK ON FINAL - - OK TO INSULATE & HANG ROCK -
---	------	--

Comments: