

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20172533  
Address: 265 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Mark Harding	Passed	Friday, November 20, 2020

Informational:

1	Misc	Bldg # 16 grade beams (2) #5 continuous 3/31/20 perimeter footing for garages (4) #5 cont 4/7/20 grade beams garages 4/17/20 stem walls @ garages OK to pour
---	------	---

**Comments:**