CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20201094Address:4408 SW TANZANITE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, November 20, 2020
Corrective Action Required:			
1 Misc	 -Complete final grade and sod -Complete stone/siding at garage -Splash blocks at all sump pump and downspout discharge locations, minimum 36" clearance from foundation -Seal around exterior light fixtures -Seal all penetrations in siding, seal along top of AC disconnect and meter can -Install handle/lock at sliding patio door -two locking devices required at sliding patio door -Remove all paint covers from smokes -Label dedicated outlets in garage and unfinished basement as not GFCI protected 		

Comments: