

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200719
Address: 342 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|----------------|----------|---------------------------|
| Water Service Inspection - Commercial | Ronald Paynter | Partial | Friday, November 20, 2020 |

Informational:
1 Misc Water tapped the main line with a 2 inch tap. Larry Bair set the water meter and vault to the correct elevation. They ran copper from the main to the meter and 10 feet pass the meter. RP 11-19-20

Comments: