CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202309

Address: 1717 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Footing Inspection - Residential John Morris Partial Tuesday, October 06,

2020

Corrective Action Required:

1 Misc POUR AT OWN RISK

-Provide updated drawings & engineer report to reflect field changes and

additions of footings & foundation wall

Comments: