

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202309  
Address: 1717 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Mark Harding	Failed	Monday, November 23, 2020

Corrective Action Required:

1 Misc

-Provide updated drawings & engineer report to reflect field changes and additions of footings & foundation wall.

Update- Revised plans have not been submitted as of 11/23 for the rear walkout retaining wall for the rear garage entry.  
Please submit the plot plan showing retaining wall and elevation changes.  
MARK HARDING 11/23/2020 9:36 AM

**Comments:**