

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193664
Address: 1713 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Failed	Monday, November 23, 2020

Corrective Action Required:

1	Misc	-No sidewalk inspection on record, contact development services to resolve this issue -Remove trash and construction debris -Provide gutters and downspouts -Downspouts and sump piping to discharge minimum 36 inches from foundation -Final grade and sod per approved plot -Remove dryer vent termination screen -complete cooktop installation
---	------	--

Comments: